



LIPA / KEYSpan EQUIPMENT



LIPA Spec.	Navtech Cat. No	Size Description	Amps	Volts	List Price
TRANS-S	TS-400-208(1)	41x20x10	400	600	\$1,540.00
TRANS-S	TS-400-208(3)	41x20x10	400	600	1,710.00
TRANS-S	TS-400-208 SS	41x20x10	400	600	4,250.00
TRANS-S	TS-800-208(1)	48x24x10	800	600	1,880.00
TRANS-S	TS-800-208(3)	48x24x10	800	600	2,200.00
TRANS-S	TS-800-208 SS	48x24x10	800	600	5,500.00
6J-7PTS	MS7PTS	7 PT. METER SOCKET	30 AMP (CONT)	240	570.00
13J-10PTS	MS10PTS	10 PT. METER SOCKET	30 AMP (CONT)	240	620.00
TRANS-S & REMOTE	RTS-400(1)	41x20x10	400	600	940.00
TRANS-S & REMOTE	RTS-400(3)	41x20x10	400	600	1,050.00
TRANS-S & REMOTE	RTS-800(1)	48x24x10	800	600	1,880.00
TRANS-S & REMOTE	RTS-800(3)	48x24x10	800	600	2,110.00



LIPA 800 AMP TRANS "S"

CURRENT TRANSFORMER CABINET (NEMA 3R)


400 AMP. 600 AMP. & 800 AMP., 240 V

CATALOG NUMBER TS-800-208(1) TS-800-208(3)


RTS-800(1) RTS-800(3)




BOTTOM VIEW



TOP VIEW



SIDE VIEW



- CABINET SHALL BE RATED NEMA 3R AND SHALL BE CONSTRUCTED FROM CODE GAUGE GALVANIZED OR GALVANNEALED STEEL.
- BUS BAR SHALL BE SILVER OR TIN PLATED AND SHALL BE SIZED PER THE NEC.
- BUS BAR SHALL BE MOUNTED IN THE CABINET BY MEANS OF STANDOFF INSULATORS OR INSULATED MOUNTING BRACKETS. INSULATING MATERIAL SHALL CONFORM TO THE APPLICABLE SECTIONS OF UL 746 AND UL 94. CABINET SHALL BE UL APPROVED.
- THE RIGHT HAND SIDE OF THE CABINET SHALL ALLOW FOR LINE AND LOAD CABLES TO ENTER AND EXIT THROUGH THE BOTTOM OF THE CABINET. THIS SPACE SHALL ALLOW FOR THE CABLES TO MEET THE MINIMUM BENDING RADIUS TO NEAREST PHASE OR NEUTRAL BUS AS PER THE NEC.
- THE SHORT CIRCUIT WITHSTAND CAPABILITY OF THE CABINET ASSEMBLY SHALL BE A MAXIMUM OF 50,000 RMS SYMMETRICAL AMPERES.

- CABINET DESIGN SHALL HAVE PROVISIONS FOR A SOLID DOOR TO ALLOW FOR THE METER ENCLOSURE TO BE MOUNTED REMOTELY FROM THE CABINET.
- MANUFACTURER SHALL FURNISH AND INSTALL 1/2-13 STUDS WITH SPLIT LOCK WASHERS AND HEX NUTS FOR CT MOUNTING.
- USE ONLY MANUFACTURER'S APPROVED LUG PROVIDED. 2 LUGS/PER TERMINAL, EACH RATED FOR (1) 600 MCM-#4 OR (2) 250 MCM-#4 CABLE.
- ONLY FACTORY PREFABRICATED KNOCKOUTS ON THE ENCLOSURE SHALL BE USED.**
- PROVIDE PREWIRED TRANS "S" UNIT IN ACCORD WITH LIPA CONSTRUCTION STANDARD: #8908A FOR SINGLE PHASE, 3 WIRE FORM 4S, OR CONSTRUCTION STANDARD #8509A FOR 3 PHASE, 4 WIRE WYE FORM 9S METER SOCKET.